



NOTES:

1. MINIMUM 12" OVERLAP OF ALL SEAMS REQUIRED.
2. BARRIER REQUIRED AT TOE OF SLOPE
3. COVERING MAINTAINED TIGHTLY IN PLACE BY USING SANDBAGS OR TIRES ON ROPE WITH A MAXIMUM 10' SPACING IN ALL DIRECTION

Modified from California Stormwater BMP Handbook

NTS

City of Springfield, Missouri



Department of Public Works
Storm Water Services Division

PLASTIC SHEETING

Figure: EC-12
Issued: 10-01-2008
Revised: